

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0055470
 Drilling Permit No. 854228
 Water right or injection well # _____

2. OWNER:
 Name Westslope Properties
 Address 687 W Canfield Ave Ste 101
 City Coeurd'Alene State ID Zip 83815

3. WELL LOCATION:
 Twp. 58 North or South Rge. 4 East or West
 Sec. 7 _____ 1/4 NW 1/4 SE 1/4
10 acres 40 acres 160 acres

Gov't Lot _____ County Bonner
 Lat. _____ (Deg. and Decimal minutes)
 Long. _____ (Deg. and Decimal minutes)
 Address of Well Site Gleason/McAbee Falls Rd
(Give at least name of road + distance to Road or Landmark) City Priest River
 Lot. 4 Blk. _____ Sub. Name Murry Crk

4. USE:
 Domestic Municipal Monitor Irrigation Thermal Injection
 Other _____

5. TYPE OF WORK:
 New well Replacement well Modify existing well
 Abandonment Other _____

6. DRILL METHOD:
 Air Rotary Mud Rotary Cable Other _____

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
bentonite	0	18	300lbs	overbore

8. CASING/LINER:

Diameter (nominal)	From ft	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6	+1 1/2	88 1/2	250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4	-5 1/2	305	160	pvc	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used? Y N Shoe Depth(s) 88 1/2

9. PERFORATIONS/SCREENS:
 Perforations Y N Method saw
 Manufactured screen Y N Type slotted pvc
 Method of installation _____

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
160	180	1/8 x	5 22		pvc	
275	285	10		4"	pvc	

Length of Headpipe _____ Length of Tailpipe _____
 Packer Y N Type _____

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method

11. FLOWING ARTESIAN:
 Flowing Artesian? Y N Artesian Pressure (PSIG) _____
 Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:
 Depth first water encountered (ft) 158 Static water level (ft) 80
 Water temp. (°F) cold Bottom hole temp. (°F) _____
 Describe access port cap

Well test: _____ Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
			<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	4gpm	60				

Water quality test or comments: clear

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
8	0	18	brown silty sand		
6	18	80	brown silty sand		
	80	88	decomposed granite		
	88	160	brown&white granite	x	
			soft spots thru-out	1gpm	
	160	205	firm brown&white granite		
	205	305	salt&pepper granite	x	
			soft spots thru-out	3gpm	

RECEIVED
 DEC 03 2008
 NDWR/North

ENTERED
 11/22/08

Completed Depth (Measurable): 305ft
 Date Started: 11-13-08 Date Completed: 11-17-08

14. DRILLER'S CERTIFICATION:
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Bronson Water Wells Co. No. 360

*Principal Driller Clint Bronson Date 11/24/08

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.

58N 04W 07